
408

JUL 6 1985

# AIRCRAFT HAND FIRE EXTINGUISHERS 1965





Fifty Cents

Copyright © 1965

NATIONAL FIRE PROTECTION ASSOCIATION

International

60 Batterymarch Street, Boston, Mass. 02110

# National Fire Protection Association

International

#### Official NFPA Definitions

Adopted Jan. 23, 1964. Where variances to these definitions are found, efforts to eliminate such conflicts are in process.

SHALL is intended to indicate requirements.

Should is intended to indicate recommendations or that which is advised but not required.

APPROVED means acceptable to the authority having jurisdiction. The National Fire Protection Association does not approve, inspect or certify any installations, procedures, equipment or materials nor does it approve or evaluate testing laboratories. In determining the acceptability of installations or procedures, equipment or materials, the authority having jurisdiction may base acceptance on compliance with NFPA or other appropriate standards. In the absence of such standards, said authority may require evidence of proper installation, procedure or use. The authority having jurisdiction may also refer to the listings or labeling practices of nationally recognized testing laboratories, \* i.e., laboratories qualified and equipped to conduct the necessary tests, in a position to determine compliance with appropriate standards for the current production of listed items, and the satisfactory performance of such equipment or materials in actual usage.

\*Among the laboratories nationally recognized by the authorities having jurisdiction in the United States and Canada are the Underwriters' Laboratories, Inc., the Factory Mutual Engineering Division, the American Gas Association Laboratories, the Underwriters' Laboratories of Canada, the Canadian Standards Association Testing Laboratories, and the Canadian Gas Association Approvals Division.

LISTED: Equipment or materials included in a list published by a nationally recognized testing laboratory that maintains periodic inspection of production of listed equipment or materials, and whose listing states either that the equipment or material meets nationally recognized standards or has been tested and found suitable for use in a specified manner.

LABELED: Equipment or materials to which has been attached a label of a nationally recognized testing laboratory that maintains periodic inspection of production of labeled equipment or materials, and by whose labeling is indicated compliance with nationally recognized standards or the conduct of tests to determine suitable usage in a specified manner.

AUTHORITY HAVING JURISDICTION: The organization, office or individual responsible for "approving" equipment, an installation, or a procedure.

#### Units of Measurements

Units of measurements used here are U. S. standard. 1 U. S. gallon = 0.83 Imperial gallons = 3.785 liters. One foot = 0.3048 meters. One inch = 25.40 millimeters. One pound per square inch = 0.06805 atmospheres = 2.307 feet of water. One pound = 453.6 grams.

#### Copyright and Republishing Rights

This publication is copyrighted © by the National Fire Protection Association. Permission is granted to republish in full the material herein in laws, ordinances, regulations, administrative orders or similar documents issued by public authorities. All others desiring permission to reproduce this material in whole or in part shall consult the National Fire Protection Association.

# Standard on Aircraft Hand Fire Extinguishers

NFPA No. 408 — 1965

#### 1965 Edition of NFPA No. 408

This standard was adopted at the 1965 NFPA Annual Meeting held in Washington, D.C., May 17–21. It revises and replaces the 1964 edition following action by the sponsoring Sectional Committee on Aircraft Maintenance and Servicing to whom this project was assigned by the parent NFPA Committee on Aviation. The principal change in the 1965 Edition as compared with the 1964 Edition is the recommendation against the use of dry chemical extinguishers which were previously recognized for limited application in aircraft compartments (see particularly Paragraph 312 herein). Other changes made were to clarify the intent and to add helpful guidance on the use of extinguishers in aircraft. Paragraphs reflecting these revisions are 210, 311, 312, 322, 422.c, d, and f., A-20, A-31, and A-32. Other minor editorial and reference changes and deletions were made as necessary.

# Origin and Development of No. 408

Work on this standard started in 1947 after requests had been received by the National Fire Protection Association for recommendations on aircraft hand fire extinguishers. During the intervening years, prior to the adoption of the first draft of this text in 1955 by the Association, a number of proposals were prepared and circulated for comment and criticism. In 1956 a revision was adopted incorporating an Appendix on air crew training. A revision was made in 1964 and the current edition contains the latest recommendations of the Association.

It is the intent of this standard to supplement existing governmental regulations, as they may affect aircraft operators, in the provision for and selection of aircraft hand fire extinguishers. Where governmental regulations are not applicable, it is hoped that this standard will be a useful guide to those interested.

#### Committee on Aviation

Jerome Lederer, † Chairman.

Flight Safety Foundation, 468 Park Avenue South, New York, N. Y. 10016

Harvey L. Hansberry (SFPE), Vice-Chairman,

Federal Aviation Agency, Aircraft Branch RD-740, Systems Research & Development Service, Federal Aviation Agency, Atlantic City, N. J. 08405

George H. Tryon (SFPE), Secretary,

National Fire Protection Association, 60 Batterymarch St., Boston, Mass, 02110

- C. Abbott, British Overseas Airways Corp. (Personal)
- F. Blumel, Jr., American Airlines. Chairman of Sectional Committee.
- Henry G. Bone, Jr., The Boeing Co. (Personal)
- Thomas Burnard, Airport Operators Council.
- H. L. Butler, Eastern Air Lines. (Personal)
- C. Byrus. University of Maryland. Chairman of Sectional Committee.
- John J. Carroll, Civil Aeronautics Board.
- M. Chase, Flight Safety Foundation. Chairman of Sectional Committee.
- N. L. Christoffel, United Air Lines. (Personal)
- C. W. Conaway, Factory Insurance Association.
- G. T. Cook, Department of the Air Force. Robert F. Farrell, United States Aviation
- Underwriters.
- B. V. Hewes, Airline Pilots Assn.
- H. Prater Hogue, The Boeing Company. (Personal)
- Charles H. Kaman, Vertical Lift Council, Aerospace Industries Assn. of America, Inc.
- G. C. Koth, Factory Mutual Engineering Division.

- Dan Mahanev.† Federal Aviation Agency.
- James S. Mathews, Associated Aviation Underwriters.
- C. M. Middlesworth, † Federal Aviation Agency.
- J. A. O'Donnell, American Airlines. Chairman of Sectional Committee.
- E. Parker, Australian Dept. of Civil Aviation.
- R. C. Petersen, Port of New York Authority. (Personal)
- H. B. Peterson, U. S. Naval Research Laboratory.
- W/C B. C. Quinn, Canadian Department of National Defence.
- E. E. Reed, American Petroleum Institute. George Schrank, Fire Equipment Manu-
- facturers Association. S. W. Sheat, United Kingdom, Ministry of
- Aviation John T. Stephan, American Association of
- Airport Executives. E. F. Tabisz, Underwriters' Laboratories of
- R. H. Tolson, American Petroleum Institute. Douglas C. Wolfe, American Association of Airport Executives.

#### Alternates.

Alternate to Mr. Burnard

Ross A. KNIGHT (Airport Operators Council)

Alternate to Mr. Hewes

WILLIAM L. COLLIER (Air Line Pilots Association)

Alternate to Mr. Conaway

F. J. McClain (Factory Insurance Association)

Alternate to Mr. Cook

ROSCOE L. BELL (Dept. of the Air Force)

Alternate: American Ins. Assn.

CHARLES S. RUST (Appointment of principal pending)

Alternate to Mr. Tablsz
G. L. Toppin (Underwriters' Laboratories of Canada)

Alternate to Mr. Tolson and Mr. Reed C. F. II. Institute) F. REINHARDT (American Petroleum

#### Liaison Representatives,†

Allen W. Dallas, Air Transport Association

S. Krzyczkowski, International Air Transport Association W. A. McGowan, National Aeronautics and Space Administration

Dr. A. F. Robertson, National Bureau of Standards E. J. C. Williams, Air Ministry, United Kingdom

Chief, Aerodromes, Air Routes and Ground Aids Section, International Civil Aviation Organization

# Sectional Committee on Aircraft Maintenance and Servicing

Joseph M. Chase, Chairman, Flight Safety Foundation, 468 Park Avenue South, New York, N. Y. 10016

> N. L. Christoffel, Vice-Chairman, United Air Lines, P.O. Box 8800, Chicago, Illinois 60666

- J. C. Abbott, British Overseas Airways Corp.
- N. W. Andrews, Grumman Aircraft Engineering Corp.
- Henry G. Bone, Jr., The Boeing Co.
- G. A. Brelie (SFPE), The Ansul Co.
- Flight Lt. A. E. Graham, Royal Canadian Air Force, Dept of National Defence.
- Stuart C. Hand (SFPE), J. S. Frelinghuysen Corp.
- Harvey L. Hansberry (SFPE), (ex-officio), Federal Aviation Agency.
- G. C. Koth (SFPE), Factory Mutual Engineering Division.
- Jerome Lederer† (ex-officio), Flight Safety Foundation, Inc.
- H. J. McRae, National Safety Council.

- C. M. Middlesworth,† National Aviation Facilities Experimental Center, Federal Aviation Agency.
- R. S. Moore, Grumman Aircraft Engineering Corp.
- H. L. Morris, Eastern Air Lines.
- Roy C. Petersen (SFPE), Airport Operators Council.
- R. L. Potter, American Airlines.
- E. E. Reed, American Petroleum Institute.
- Douglas T. Rounds, Air Line Pilots Association.H. W. Schilling, Trans World Airlines, Inc.
- J. H. Sellers, Insurance Company of North America.
- R. H. Tolson, American Petroleum Institute. Kenneth A. Zuber, Compressed Gas Association.

#### Alternates.

Edwin A. Olsen, Compressed Gas Assn., Inc. (Alternate to Kenneth A. Zuber.) C. F. Reinhardt, American Petroleum Institute. (Alternate to E. E. Reed and R. H. Tolson.)

<sup>†</sup>Non-voting member.

# Table of Contents

Sec. 100. Scope	<b>408</b> -5
Sec. 200. Definitions	<b>408</b> -5
Sec. 300. Basis for Recommendations	<b>408</b> –6
Art. 310. General	<b>408</b> -6
Art. 320. Carbon Dioxide Extinguishers	<b>408</b> -6
Art. 330. Water (Water Solution) Extinguishers	<b>408</b> -7
Sec. 400. Recommendations	<b>408</b> -8
Art. 410. General	<b>408</b> -8
Art. 420. Number, Capacity and Location of Fire Extinguishers	<b>408</b> –8
Par. 421. Crew Compartment	<b>408</b> –8
Par. 422. Passenger and Buffet Compartments.	<b>408</b> –8
Par. 423. Baggage and Cargo Compartments .	408-9
Art. 403. Daily Inspections of Aircraft Hand Fire Extinguishers	<b>408</b> –10
Art. 440. Other Maintenance Procedures for Aircraft Hand Fire Extinguishers	<b>408</b> –10
Art. 450. Air Crew Training on Aircraft Hand Fire Extinguishers	<b>408</b> -10
Art. 460. Accessory Equipment	<b>408-1</b> 0
Appendix. Suggested Air Crew Training Outline	408-11

#### Standard on

# Aircraft Hand Fire Extinguishers

#### NFPA No. 408 - 1965

### 100. Scope

110. This Standard covers the type, capacity, location and quantity of aircraft hand fire extinguishers and accessory equipment provided essentially for the protection of aircraft compartments occupied by passengers and crew. Recommendations are also given for the daily inspection and periodic maintenance of aircraft hand fire extinguishers and a suggested air crew training outline is given in the Appendix.

#### 200. Definitions

- 210. Aircraft hand fire extinguishers are fire extinguishing units, manually operated, which are sufficiently portable to permit the entire unit to be transported by hand without excessive effort on the part of the operator. An approved aircraft hand fire extinguisher is defined as a fire extinguisher which is approved by the Underwriters' Laboratories, Inc., Factory Mutual Engineering Division, Underwriters' Laboratories of Canada, or other nationally recognized fire testing laboratories. The Federal Aviation Agency in the U. S. A. accepts water-based extinguishers on certification by the manufacturer that the device meets FAA Technical Standard Order C-19.
- **220.** For the purposes of this Standard, fires can be divided into three basic types:
- (a) Class A fires, defined as fires in ordinary combustible materials such as wood, cloth, paper, etc.
- (b) Class B fires defined as fires in flammable petroleum products or other flammable liquids, greases, etc.
- (c) Class C fires, defined as fires involving energized electrical equipment where the electrical nonconductivity of the extinguishing media is of importance. In most cases where electrical equipment is de-energized, extinguishers suitable for use on Class A or B fires may be employed effectively.

#### 300. Basis for Recommendations

#### 310. General

- 311. Aircraft hand fire extinguishers shall be of an approved type employing as extinguishing media only one of the following: carbon dioxide or water (water solution). The types and quantity shall be as specified in Section 400.
- 312. Among other agents not recommended for airborne use in aircraft hand fire extinguishers are dry chemical, vaporizing liquid, and the halogenated extinguishing agents. Dry chemical extinguishers are not recommended because of problems of nonconductivity of the agent in the presence of fine electrical contacts, the corrosive properties of some of the dry chemical formulations, the reduction of visibility liable to be encountered when the agent is discharged in the confined space of an aircraft cabin, and the problem of removing powder residues following extinguishment. The vaporizing liquid and halogenated extinguishing agents are not recommended because of the possible irritable nature of the decomposition products of these agents on the aircraft occupants and the obscuration factor of the smoke created when these agents are applied to a fire.

# 320. Carbon Dioxide Extinguishers

- 321. Carbon dioxide extinguishers are principally suited for fires involving flammable liquids (Class B) and electrical equipment (Class C). They are of limited value for extinguishment of incipient fires involving ordinary combustible materials (Class A) such as paper, fabric, etc. Their principal action is to "blanket" the fire by excluding oxygen.
- 322. In using extinguishers of this type, best results are obtained by directing the discharge close to the fire, applying first at edge and bottom of the fire and progressing forward and upward, moving discharge horn slowly from side to side. On electrical fires, to eliminate the primary source of trouble and to reduce the hazard of rekindling, the power to the appliance or wiring should be disconnected first wherever possible. Where electrical circuits cannot be disconnected, intermittent discharge of the extinguisher after the fire is initially extinguished may be necessary in event of reignitions.
- 323. Carbon dioxide hand type extinguishers of the capacity recommended herein can normally be used without danger of ill effects to the occupants. (See Note to Paragraph 421.a.) The carbon dioxide vapor cloud will, however, often reduce visibility temporarily in an enclosed space. The agent is noncorrosive and will not injure fabric or food.

- **324.** Where temperatures below minus 40° F. are encountered, carbon dioxide extinguishers should be winterized in an approved manner to assure maximum operational efficiency.
- 325. The agent does not deteriorate with age and the extinguisher needs to be refilled only after use. Periodic checks should be made by weighing the unit to assure full charge (correct full weight stamped on all approved types).

NOTE: Full information on the maintenance of these extinguishers is contained in the NFPA Recommended Good Practice for the Maintenance and Use of Portable Fire Extinguishers (No. 10A).

# 330. Water (Water Solution) Extinguishers

- 331. Water (water solution) extinguishers are most suitable for fires involving ordinary combustible material (Class A) such as paper, fabric, etc., where the quenching and cooling effects of water or a solution containing water are of first importance. Water extinguishers are not recommended for use on fires involving flammable liquids or energized electrical equipment or wiring.
- 332. In using extinguishers of this type, best results are obtained by directing the discharge at the base of the flames and working around the burning area. Smoldering embers should be kept under scrutiny after the bulk of the fire is extinguished.
- 333. There is no danger of toxicity. Water (water solution) extinguishers of approved types are designed to eliminate any detrimental corrosive effects which would interfere with their proper operation.
- 334. A proper degree of anti-freeze protection should be provided where necessary to assure efficient operation. Anti-freeze protection should be accomplished only in accordance with the manufacturer's instructions and with the approval of the testing agency (see Section 210 and Paragraph 442).
- 335. Discharge pressure may be secured from a small compressed gas cartridge or stored pressure. The agent does not deteriorate or evaporate with age when properly sealed and needs to be refilled only after use. Periodic checks should be made to assure full charge.

Note: Full information on the maintenance of these extinguishers is contained in the NFPA Recommended Good Practice for the Maintenance and Use of Portable Fire Extinguishers (No. 10A).

336. Normally, additional water is available from buffet and washroom facilities which may be used for soaking smoldering materials and for supplementary fire control purposes involving ordinary combustible materials.

#### 400. Recommendations

#### 410. General

411. Selection of fire extinguishers shall be based upon the facts discussed in Section 300.

WARNING: It should be noted that almost all forms of combustion (fires) produce toxic vapors, the most serious practical danger being from carbon monoxide. Enclosed areas should be vented following complete extinguishment. Premature ventilation might supply fresh oxygen to a smoldering fire which might cause reignition and extreme care is therefore required.

# 420. Number, Capacity and Location of Fire Extinguishers:

The number, capacity and location of the extinguishers shall be as follows:

## 421. Crew Compartment:

(a) Crew compartments shall contain at least one approved carbon dioxide hand extinguisher with a minimum rating of 2B:C\* to be located so as to be immediately accessible to the cockpit crew and its location made obvious by either its location or placarding.

# 422. Passenger and Buffet Compartments:

(a) In passenger compartments, the extinguishers specified in the following Subparagraphs *shall* be easily accessible at all times and *should* be clearly visible to the crew and passengers; however, if the extinguishers are not clearly visible to the crew and passengers, their location *shall* be indicated by a clearly legible placard or sign easily visible to the crew and passengers.

It is recommended that signs indicating location of extinguishers have letters at least \( \frac{3}{8} \) inch in height mounted on a contrasting background.

(b) Aircraft accommodating no more than 30 passengers shall contain a minimum of one approved water extinguisher.† In per-

<sup>\*</sup>Extinguishers are rated in accordance with the NFPA Standard on Installation of Portable Fire Extinguishers (No. 10). Carbon dioxide extinguishers having a 2B:C rating are available in sizes containing from 2 to 5 pounds of agent. Each extinguisher should be checked to determine its exact rating. Larger sizes should not be used in crew compartments unless the volume of the free air space and the natural ventilation available indicates that any carbon dioxide concentration which might result from the operation of such larger capacity devices presents no problem to the crew due to oxygen deficiency in the space or obstruction of vision.

<sup>†</sup>A minimum one quart (nominal) size is recommended. The Underwriters' Laboratories, Inc. lists a special loaded-stream water solution extinguisher for aircraft use. FAA Technical Standard Order C-19 describes extinguishers of this design and the FAA authorizes the use of extinguishers meeting this TSO on certification by the manufacturer.

sonal type aircraft where crew and passenger compartments are not segregated and 4 or more seats are provided, one approved water extinguisher† is recommended in addition to the carbon dioxide extinguisher recommended in Paragraph 421.a.

- (c) Aircraft providing space for 31 through 60 passengers shall contain a minimum of one approved water extinguisher† and one additional extinguisher which may be a carbon dioxide unit\* having a minimum 2B:C rating.
- (d) Aircraft accommodating 61 or more passengers shall have a minimum of two approved water extinguishers† and one additional extinguisher which may be a carbon dioxide unit\* having a minimum 2B:C rating. The two water extinguishers shall be located remote from each other in the compartment.
- (e) Passenger compartments or lounges, other than lavatories, separate and individually located from other passenger-occupied compartments shall have a minimum of one approved water extinguisher.† A passenger compartment or lounge shall be considered separately and individually located when it is divided from other occupied portions of the aircraft by a door, curtained opening, stairwell, or other arrangement which obscures vision or impairs air circulation, except that a berth in a sleeper plane shall not be considered a separate compartment.
- (f) Where cooking facilities are provided in a buffet or galley, one approved carbon dioxide extinguisher\* having a minimum rating of 2B:C shall be provided and this may be the "additional extinguisher" referenced in Paragraphs 422.c. and d. above.

# 423. Baggage and Cargo Compartments:

- (a) Baggage or cargo compartments of passenger-carrying aircraft accessible to crew members in flight may be provided with one approved water extinguisher† where desired. Normally, the water extinguishers provided in the passenger compartment will be available and accessible for use in such accessible baggage or cargo compartments and an extra extinguisher specifically for such compartments is not mandatory.
- (b) No hand fire extinguishers are required for baggage or cargo compartments of passenger-carrying aircraft which are not accessible to crew members in flight.
- (c) Crew compartments of all-cargo type aircraft shall be provided with extinguishers as specified in Paragraph 421. Protection

<sup>\*</sup>See first footnote, page 408-8.

<sup>†</sup>See second footnote, page 408-8.

of cargo compartments of all-cargo type aircraft requires individual study as to the desirability and practicality of providing hand fire extinguishers. It is not considered practical to attempt to carry sufficient hand fire extinguishers to deal with a major cargo fire. The accessibility of the cargo, the internal air circulation, the facilities for depressurization, the insulation of the cargo compartment, the nature of the cargo, and the provision of fixed fire extinguishing equipment and the availability of fire detection equipment in such spaces influence the need for and type of hand fire extinguishers which might be required.

# 430. Daily Inspections of Aircraft Hand Fire Extinguishers

431. The daily inspections shall include: (1) a check that aircraft hand fire extinguishers are in their proper location, (2) that seal wires are in place, and (3) that pressure gage indicates proper pressurization on stored-pressure type equipment.

# 440. Other Maintenance Procedures for Aircraft Hand Fire Extinguishers

- 441. Aircraft hand fire extinguishers shall be maintained in accordance with the provisions of the NFPA Recommended Good Practice for the Maintenance and Use of Portable Fire Extinguishers (No. 10A) in so far as applicable.
- 442. Water extinguishers that are protected from freezing by corrosive additives (such as calcium chloride or alkali metal salt solutions) shall be discharged every six months to determine that they operate properly unless the manufacturer certifies that no corrosion hazard exists and this is substantiated by the tests of a nationally recognized fire testing laboratory.

# 450. Air Crew Training on Aircraft Hand Fire Extinguishers

451. Initially, before assignment, and annually thereafter, air crews shall receive training in the use of aircraft hand fire extinguishers. A suggested training outline is given in the Appendix.

# 460. Accessory Equipment

- 461. It is also recommended that a device be provided suitable for ripping cabin wall linings and seat upholstery in event of a concealed or smoldering fire in such areas.
- 462. Where extinguishers recommended above operate by carbon dioxide cartridges, one extra cartridge for each such unit should be carried aboard the aircraft where recharges of the basic extinguishing agent are also available. (This applies to water type devices.)

# Appendix Suggested Air Crew Training Outline On Use of Aircraft Hand Fire Extinguishers

- A-10. In compliance with Paragraph 451, aircraft crew members should be given opportunities to use the aircraft hand fire extinguishers provided so that they might become proficient in the use of these devices and be able to judge in actual fire situations the best type or types of extinguishers which might be used with maximum efficiency. A recurrent training program should be established.
- A-20. Aircraft hand fire extinguishers recommended herein include those employing carbon dioxide or water (water solution). Aircraft crews should be given training using the types of appliances actually provided on the aircraft they operate and serve.
- A-30. The following outline to provide aircraft crews with the desired familiarity with aircraft hand fire extinguishers may be helpful.

WARNING: Instructors should practice these test fires beforehand and know what to anticipate. Be sure to light gasoline fires from the upwind side and prearrange method of ignition of fires to assure safety.

- A-31. Training with carbon dioxide extinguishers designed for Class B fires should be as follows:
  - (a) Materials needed:
    - 1. Gasoline (in safety can).
- 2. One metal pan or tub about 18 inches in diameter and 4 inches high.
  - 3. A supply of shredded paper.
- 4. One 15-pound carbon dioxide or dry chemical extinguisher and a  $2\frac{1}{2}$ -gallon water extinguisher for emergency use.
- 5. One or more of the aircraft carbon dioxide and water extinguishers to be used for the tests.
  - (b) Test fire suggestions:
- 1. In a safe location outdoors, spill some gasoline along the ground in a narrow strip (4 or 5 inches wide) for a distance of about 5 feet. Light one end and have trainees extinguish with the aircraft carbon dioxide extinguisher in the manner described in Paragraph 322.
- 2. In a safe location outdoors, pour some gasoline in a metal pan or tub about 18 inches in diameter and 4 inches high. (The gasoline may be floated on water to conserve the fuel. Leave at least one-inch "freeboard.") Ignite the gasoline and have trainees